

☒ UNCLASSIFIED

☐ INTERNAL
USE ONLY

☒ CONFIDENTIAL

☐ SECRET

Approved For Release 2001/03/06 : CIA-RDP86-00800R000100150006-6
ROUTING AND RECORD SHEET

SUBJECT: (Optional)

Request for Delegation of Authority

FROM:

Chief, Real Estate and
Construction Division, OL

EXTENSION

8111

NO.

DATE

TO: (Officer designation, room number, and
building)

DATE

RECEIVED

FORWARDED

OFFICER'S
INITIALS

COMMENTS (Number each comment to show from whom
to whom. Draw a line across column after each comment.)

1. AGC/OL

4/7

see

1. APPROVAL as to legal form

*with the PRIORITY
stickers there?*

2.

3. D/L

8 APR 1976

15

3. SIGNATURE

4.

DD/L

8 APR 1976

2

5.

EO/OL

7 APR 1976

0

6.

AED/OL

7 APR 1976

W

7.

04/0000

8.

[REDACTED]

9.

10.

11.

12.

13.

14.

15.

File

25X1A6a

25X1A

SPEED LETTER

REPLY REQUESTED

DATE

2 Apr 75

YES

NO

LETTER NO.

TO :

FROM:

C/FEB/RECD/OL

ATTN:

Subj: Water line installation

25X1A6a

1. The drawings and specs for the water line installation contract and the grounds maintenance contract, [REDACTED] have been reviewed with the following comments:

Water line installation

Specifications for cast iron pipe, Section 15A-page 2, require a working pressure of 250 p.s.i. This should be changed to require a test pressure of 250 p.s.i.

Grounds maintenance

- a. Minimum distance should be specified for mowing around pond, fire trails, and gravel roads. Distance could be in feet or to a boundary such as wooded area.
- b. Specify the degree of clean-up of grass and trimmings for roads and walks.
- c. Specify a maximum height for grass after each cutting.
- d. Specify a minimum distance from the entrance road for leaf removal.
- e. Indicate locations of chain link fence.

SIGNED

25X1A9a

REPLY

DATE